

California Certification

State of California
 Department of Health Services
Water Treatment Device
Certificate Number
 05 - 1736

Date Issued: October 20, 2005

Trademark/Model Designation	Replacement Element(s)
Multi-Pure MPAD	CB6AD
Multi-Pure MPADC	CB6AD

Manufacturer: Multi-Pure Drinking Water Systems

The water treatment device(s) listed on this certificate have met the testing requirements pursuant to Section 116830 of the Health and Safety Code for the following health related contaminants:

Microbiological Contaminants and Turbidity	Inorganic/Radiological Contaminants
Cysts	Asbestos
Turbidity	Lead
	Mercury
Organic Contaminants	
Chlordane	Simazine
MTBE	Styrene
PCB	1,1,2,2-Tetrachloroethane
Toxaphene	Tetrachloroethylene
VOCs	Toluene
Alachlor	2,4,5-1P (Silvex)
Atrazine	Tribromoacetic Acid
Benzene	1,2,4-Trichlorobenzene
Carbofuran	1,1,1-Trichloroethane
Carbon Tetrachloride	1,1,2-Trichloroethane
Chlorobenzene	Trichloroethylene
Chloropierin	Trihalomethanes (THMs)
2,4-D	Bromodichloromethane
DBCP	Bromoform
o-Dichlorobenzene	Chloroform
p-Dichlorobenzene	Chlorodibromomethane
1,2-Dichloroethane	Xylenes
1,1-Dichloroethylene	
cis-1,2-Dichloroethylene	
trans-1,2-Dichloroethylene	
1,2-Dichloropropane	
cis-1,3-Dichloropropylene	
Dinoseb	
Endrin	
Ethylbenzene	
EDB	
Halacetonitriles (HAN)	
Bromochloroacetonitrile	
Dibromoacetonitrile	
Dichloroacetonitrile	
Trichloroacetonitrile	
Haloketones (HK)	
1,1-Dichloro-2-Propanone	
1,1,1-Trichloro-2-Propanone	
Heptachlor	
Heptachlor Epoxide	
Hexachlorobutadiene	
Hexachlorocyclopentadiene	
Lindane	
Methoxychlor	
Pentachlorophenol	

Rated Service Capacity: 750 gals

Rated Service Flow: 0.75 gpm

Do not use where water is microbiologically unsafe or with water of unknown quality, except that systems certified for cyst reduction may be used on disinfected waters that may contain filterable cysts.



Multi-Pure
Drinking Water Systems

Las Vegas, NV 89128

BR170CB-MPADC-0603